

CERTIFICATE

Fire extinguishers

This is to confirm that the below stated "BAVARIA" DIN EN 3 fire extinguisher with 6 kg ABC dry chemical powder is approved in accordance with DIN EN 3-7 as well as on basis of the available test reports for fire extinguishing purposes for the fire classes **A, B and C** according to DIN EN 2 under the following certification number:

SP 84/10

Test report according to annex C of EN 3-10, No.: 2009-F-2264/EG 80

Holder of certificate: BAVARIA EGYPT S.A.E., 17, Emad El Din St., 11111 Cairo, Egypt

Manufacturer: BAVARIA EGYPT S.A.E., Gisir El Suez St. Block 109-Industrial Zone,
Ismailia Desert Road, 11511 Cairo, Egypt

Model name of the
fire extinguisher: Phoenix 6

Drawing No.: 06-77006
Component list No.: 06-77006

Fire extinguishing
medium: ABC BAVARIA EXTRA POWDER
Cert. No. SP 67/09

Operation device: Plastics valve with
handle and lever

Propellant: Nitrogen, 15 bar at 20°C

Special detail: Nozzle diameter 5,3 mm

Test fire rating: 43 A and 233 B according to DIN EN 3-7

Temperature
operation range: -30 °C to 60 °C

Information: The plastics operations device is tested according to EN 3-8, test report No.P-IS-DDG-MUC-08-12-338778-004-021.

The fire extinguisher is tested in accordance with DIN EN 3. Conformity to DIN EN 3 is confirmed.

The given certification number **SP 84/10** is to state in section 4 of the extinguisher label according to DIN EN 3-7.

This certificate is valid for fire extinguishers only, those comply with the submitted documents and test samples.

This certificate is valid for fire extinguishers only, those are subjected to a quality assurance system during manufacture.

The quality assurance system shall include the valid requirements of the standard DIN EN 3 concerning factory production control.

The holder of certificate is entitled to put up the above stated certification number on the fire extinguisher as long as the results of our regular inspection of manufacture in accordance with DIN EN 3 are satisfactory.

The above mentioned European standards relate to the editions which were valid at the date of this certification.

31 May 2010



Grad. Eng. A. Ullmann
Manager of the certification office



MPA Dresden GmbH
Fuchsmühlenweg 6F
09599 Freiberg
Tel. +49(0)3731-20393-0
Fax +49(0)3731-20393110

Geschäftsführer: Thomas Hübler
Steuernummer: 220/114/03011
Amtsgericht Chemnitz HR B 21581
www.mpa-dresden.de
Email info@mpa-dresden.de

Kreissparkasse Freiberg
Poststraße 1a
09599 Freiberg
Kto. 3115024672
BLZ 870 520 00

USt-IdNr. DE234220069
IBAN DE68 8705 2000 3115 0246 72
BIC WELADED1FGX